

\* \* \* \* \*

ROBERT ADAMS, PINETOP, )  
KENTUCKY, TO DEVIATE FROM )  
COMMISSION REGULATION 807 KAR ) Case No. 8257  
5:026E, SECTION 6. SUBSECTION 6 )

2. Mr. Adams should be granted permission to use 1-1/4 inch plastic pipe in lieu of black steel pipe provided the pipe is of an approved type and the entire service line is buried a minimum of 36 inches.

3. The completed service line installation should be inspected by Commission staff members prior to the filling of the ditch.

4. Mr. Adams should notify the Commission when construction is sufficiently completed to allow for the above inspection.

5. The plastic pipe should be installed by persons who qualify under O.P.S.O. requirements.

6. This service line should be used only to serve one dwelling as required by state law.

7. Mr. Adams should meet all other requirements of Public Service Commission Regulation 807 KAR 5:026E, Section 6, in his installations.

IT IS THEREFORE ORDERED that Robert Adams be and he hereby is granted authority to deviate from Public Service Commission Regulation 807 KAR 5:026E, Section 6, Subsection 6, and install 1-1/4 inch plastic pipe of an approved type for his service line, said pipe to be buried a minimum of 36 inches.

IT IS FURTHER ORDERED that Mr. Adams shall notify the Commission when construction is sufficiently completed to allow for the inspection and approval of the line by the Division of Utility Engineering and Services of the Public Service Commission before service is rendered.

Done at Frankfort, Kentucky, this 27th day of July, 1981.

PUBLIC SERVICE COMMISSION

Martin H. Voth  
Chairman

Katherine Bussell  
Vice Chairman

Ann Hargrave  
Commissioner

ATTEST:

\_\_\_\_\_  
Secretary